

| TITLE 24 SECTION | YES | NO | N/A | COMMENTS |
|--|-----|----|-----|---|
| Comfortable Living Environment [102(c)6] A comfortable living environment is maintained through an adequate heating and cooling system. | X | | | |
| Exercise Area -Type II, III and WA IV (2.10) At least one exercise area must contain a minimum of 900 square feet | X | | | Two outdoor (2) yards @ 3300 square feet each. |
| 8-86: Outdoor exercise area provided | X | | | |
| 8-86: Clear height of 15 feet with required surface area meeting a formula of: 80% of maximum rated inmate population and number of one-hour exercise periods per day = required surface area | X | | | Nine (9) scheduled periods daily (M-F) for each yard with supplemental and make-up on the weekends. |
| Program Space - Type II and III (2.11) Sufficient area and furnishings to meet the needs of the facility programs | X | | | |
| Dining Facilities (2.17) 15 square feet per inmate being fed | | | X | Meals are served in the dayrooms. |
| Toilets, washbasins and showers are not in the same room or not in view of inmate dining | X | | | |
| Visiting (2.18) Sufficient visiting area | X | | | |
| Contact visits whenever possible for minimum security inmates | X | | | |
| Attorney Interviews (2.26) Provide for confidential attorney consultation | X | | | |
| Safety Equipment Storage (2.19) Adequate space is provided for storage of equipment such as fire extinguishers, SCBA, emergency lights, etc. | X | | | |
| Janitor Closet (2.20) Located in security areas lockable, containing a mop sink and storage space | X | | | |
| Storage Rooms (2.21) Sufficient space to accommodate inmate property, bedding and supplies | X | | | |
| Audio or Video Monitoring System -NA Type IV (2.22) Audio monitoring system capable of alerting staff in a central control | X | | | |
| Video monitoring in corridors, main entries and/or exits and programs or activity areas | X | | | |